



Notes:

1- Common and controller wire to be bundled using electrical tape at 10'-0" on center.

2- Grounding rods shall be located between 8'- 0" to 12'- 0" away from the controller. Grounding rods shall be $\frac{3}{8}$ " in diameter x 8' in length. Connect the grounding rod to the controller using 6 gauge bare copper wire or per the manufacturer's specifications. See grounding rod detail.

3- ET Station shall be installed no further than 90' away from the controller and a minimum of 15' off of the ground, out from under any overhead obstructions such as, but not limited to, building overhangs, trees, or utilities.



WALL MOUNTED CONTROLLER